

Technical Service Bulletin

KM3211WH quick connect cables & system controllers

It has come to our attention that there are installations involving 2 or more units manifolded together using either the quick connect cable or a system controller.

In this situation if the units are fitted without a temperature controller then the units will not operate as expected, they will not stage depending on demand and they will not rotate the 'main' unit after 8 hours of use.

In all situations where either a quick connect cable or a systems controller is used a temperature controller **MUST** be fitted to enable the units to operate to specification.